

## GREATER WARANGAL MUNICIPAL CORPORATION

**From**  
The Commissioner,  
Greater Warangal Municipal Corporation  
Warangal.

**To**  
Bommineni Govardhan Reddy,  
Flat No.43, Mokila K.V Rangareddy  
Rangareddy.

**RC.No.HO/DFO/E-133822/GWMC/SCHL/2023, Date: 04.02.2023**

**Sub:-** Greater Warangal Municipal Corporation –Fire Prevention Wing–Issuance Renewal of No objection certificate for occupancy to the M/s Sri Srinivasa Educational Society.Sy No. 113/B, H.No.27-10-109, Erragattu, Hasanparthy, Hanumakonda mandal & district. - Reg.

- Ref:-**
1. RC.No. 5041/B2/97, Dt: 12-03-2010 of Director General, A.P. State Disaster Response and Fire Services, A.P Hyderabad.
  2. Application of the Secretary Sri Bommineni Govardhan Reddy Flat No 43 Mokila, K.V Rangareddy, Rangareddy district. Dt: 31.01.2023.
  3. Renewal of NOC for occupancy vide Ack No.345390002020, Dated: 13-11-2020.of the DGFS,TG,HYD.
  4. Note approval of Commissioner, GWMC vide file no.E-133822Date: 02.02.2023.

\*\*\*\*\*

vide reference 2<sup>nd</sup> cited the Director Sri Bommineni Govardhan Reddy submitted an application for requesting to issue renewal of NOC for occupancy to the M/s M/s Sri Srinivasa Educational Society.Sy No. 113/B,, H.No. 27-10-109, Erragattu Hasanparthy, Warangal district. Under the powers delegated vide ref. 1<sup>st</sup> cited, the Officers of Fire Prevention Wing, GWMC Warangal have inspected the premises of above non-multstoried Educational building(B1) on 01.02.2023 and submit the following report.

The management has obtained Renewal of NOC for occupancy vide reference 3<sup>rd</sup> cited to the Non Multi storied Educational building with Ground+2Upper Floor with a height of 12.00 Mts for educational occupancy(B1).with total built up area 3244.86 Sq. Mts.

**1)Floor wise details given below**

Sl.No	Floor Type	Type of Occupancy	Built Up Area in Sq. Mts	Occupant Load
1.	Ground Floor	Educational (B1)	1081.62	200
2.	First Floor	Educational (B1)	1081.62	200
3.	Second Floor	Educational (B1)	1081.62	200

**2) Travel distance & Dead end of the corridor**

Sl.No.		Required	Provided	Deficit
1	Farthest point ( Most Remote Point) Within a storey or a mezzanine floor to the door to an Exit.	30 Mts	30 Mts	-----
2.	The Dead end of the corridor length in exit access. (not exceeding 06 meters for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00 Mts	6.00 Mts	-----

**3) Open spaces and gate width**

	Sl.No	Open Spaces (in Meters as per GO.MS.No.168)	As per Occupancy NOC	Provided	Deficit
<b>a</b>	1	FRONT	6.00 mts	6.00 mts	-----
	2	REAR	11.00 mts	11.00 mts	-----
	3	SIDE 1	15.00 mts	15.00 mts	-----
	4	SIDE 2	6.00 mts	6.00 mts	-----
<b>b</b>	Sl.No	Gate Width As per NBC 2005	Required	Provided	Deficit
	1	Entry gate width	4.5 mts	4.5mts	-----
	2	Entry Gate Head Clearance	5 mts	5 mts	-----

**4) Stair Cases (As per NBC 2005)**

S.No	Type of Staircase	No. of Staircases	Width (In Mtrs)	Floor from	Floor to
1.	Internal Staircase	1No's	1.35	Ground	Terrace
2.	External Staircase	1No's	1.20	Ground	Terrace

**5) The Following Fire Safety measures has provided as per part IV table 7 of NBC 2005.**


S.No	Fire Fighting System	Required	Provided
1.	Fire Extinguishers	18	18
2.	First Aid Hose Reel	6	6
3.	Down Commer	1	1
4	Terrace Tank	10, 000 Lts	10, 000 Lts
5	Terrace Pump LPM (Booster Pump)	450 LPM	450 LPM

The management has remitted fire precautionary fee vide GWMC cash receipt no.136773  
Dt: 31.01.2023 for Rs 10,000/- (Rupees Ten thousand Rupees only)


The management has provided fire safety systems and life safety measures such as means of escape, travel distance and dead end of the corridor as per the provisions of the National Building Code, 2005.

1. The NOC issued is confined to the Fire Safety measures to be installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use/ Occupancy or building Regularization. The owner / Occupier shall comply the Building Rules Govt. Orders as applicable.
2. Evacuation plan showing exist routes and recommended action plan be displayed at conspicuous locations and shall be exhibited at all times, all escape / exit routes shall not be locked or encroached.
3. Fresh NOC would be required for any change in occupancy or addition / alterations in the building structure as per NBC and building bye/laws.
4. The Management has to maintain Fire Safety Measures at all times in good working condition as seen during the inspection.
5. Any Loss of life or property due to Non- functioning of Fire Safety Measures and other installations shall be the responsibility of the management/ owner.
6. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
7. Additional / Alteration, if any, in the building may be verified by building authority.
8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The NOC for occupancy is valid for the period of 2(Two) year from the date of issue, it is responsibility of the owner/occupier to apply renewal of fire NOC one month before expiry of above NOC.

  
District Fire Officer  
Fire Prevention Wing  
Municipal Corporation, Warangal  
4/2/2023

Commissioner  
Greater Warangal Municipal Corporation

  
Principal 22/7/23  
TEJASWI HIGH SCHOOL  
Erragattu, Hasanparthi,  
Dist. HANUMAKONDA-506 015.